



DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8501DL0582

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Wefatherm GmbH Urentalstr. 380, D-37688 Beverungen
Distributor <i>Vertreiber</i>	Wefatherm GmbH Urentalstr. 380, D-37688 Beverungen
Product Category <i>Produktart</i>	Installation systems and system joints (PN 10): drinking water installation system (8501)
Product description <i>Produktbezeichnung</i>	drinking water installation system consisting of welding connectors made of plastic PP-RCT (S-KK) and pipes made of plastic PP-RCT
Model <i>Modell</i>	Wefatherm WF
Test reports <i>Prüfberichte</i>	Laboratory control test: RA7881.235181.24 from 04.04.2024 (SKZ) Type testing: 127486/17-I from 23.06.2020 (SKZ)
Test basis <i>Prüfgrundlagen</i>	DVGW CERT ZP 8500 (23.05.2022) DVGW W 534-(P) (01.07.2015)

Date of Expiry / File No. 23.06.2030 / 24-0665-WNV
Ablaufdatum / Aktenzeichen

17.07.2025 Gre A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

P. Schmidt



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvwg-cert.com
www.dvlgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Wefatherm WF	Nominal diameter: 20 mm	
Wefatherm WF	Nominal diameter: 25 mm	
Wefatherm WF	Nominal diameter: 32 mm	
Wefatherm WF	Nominal diameter: 40 mm	
Wefatherm WF	Nominal diameter: 50 mm	
Wefatherm WF	Nominal diameter: 63 mm	
Wefatherm WF	Nominal diameter: 75 mm	
Wefatherm WF	Nominal diameter: 90 mm	
Wefatherm WF	Nominal diameter: 110 mm	
Wefatherm WF	Nominal diameter: 125 mm	

certified Components***zertifizierte Bauteile / Werkstoffe***

Registr. No. <i>Registr.-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
DW-8318CS0582	PP-RCT manufacturing group 1	Wefatherm/Wefatherm PP-RCT-Rohr; SDR 7,4	Wefatherm GmbH
DW-8319CS0583	PP-RCT manufacturing group 2	Wefatherm/Wefatherm PP-RCT-Rohr; SDR 7,4	Wefatherm GmbH

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

only to use with connectors: welding connectors made of plastic (PP-RCT), type S-KK, manufacturer: Wefatherm GmbH

The hygiene suitability for drinking water is proven with "certificate of conformity hygiene" according to "Recommendation for attestation of conformity of product hygiene suitability for drinking water" of the German Federal Environment Agency (Umweltbundesamt) issued by SKZ.

